

FIRECURTAIN STANDARD – MARCH 3, 2004

General Notes: This guide specification document is provided by Raynor Door for use by design professionals in preparing project specification documents for FIRECURTAIN STANDARD overhead coiling fire counter shutters, manufactured by Raynor Doors. For more information, contact Raynor, P.O. Box 448, 1101 East River Road, Dixon, IL 61021-0448. Phone: (800) 472-9667. Phone: (815) 288-1431. Fax: (815) 288-7142. E-mail: thegarage@raynor.com Website: www.raynor.com

Raynor Territory Managers can assist architects, engineers and specifiers in the selection of Raynor products to meet the design requirements of any project. Raynor Distribution Centers, Raynor Professional Installing Distributors and the Raynor Express Fleet ensure national and regional availability and timely delivery.

Specifier notes (comment text) are shown in blue like this. Optional text [**is shown in bold with brackets like this**]. Requirements for project-specific language to be inserted are indicated like this: **<insert requirements>**. Remove specifier notes and unused optional text in final version of the specification document. Retain, edit or delete language below to suit project requirements and specifier practice.

Under CSI's MasterFormat™ the products and systems contained in this section would typically be classified as Section 08331. Change section name or number as desired.

SECTION 08331 - OVERHEAD COILING DOORS

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes: [**Manually**] [**and**] [**Electrically**] operated overhead coiling doors, operators, controls and accessories.

Specifier Note: Revise paragraph below to suit project requirements. If a reader of this section could reasonably expect to find a product or component specified in this section, but it is actually specified elsewhere, then the related section number(s) should be listed in the paragraph below. Add section numbers and titles per CSI MasterFormat and specifier's practice. In the absence of related sections, delete paragraph below.

B. Related Sections:

1. Division 5 Sections: Miscellaneous Metals for steel supports.
2. Division 8 Sections: Hardware, Locks, Access Panels.
3. Division 9 Sections: Finish Painting, Field Painting.
4. Division 11 Sections: Parking Control Equipment for remote door controls.
5. Division 16 Sections: Electrical connections and service for powered door operators.

Specifier Note: Retain, edit or delete paragraph below to suit project requirements and specifier practice.

C. Products Supplied but not Installed Under this Section: **<Insert requirements.>**

Specifier Note: Retain, edit or delete paragraph below to suit project requirements and specifier practice.

D. Products Installed but not Supplied Under this Section: **<Insert requirements.>**

Specifier Note: Article below may be omitted when specifying manufacturer's proprietary products and installation recommendations. Retain References Article when specifying products and installation by an industry reference standard. This article does not require compliance with standard. It is a listing of all references used in this section.

1.2 REFERENCES

A. General: Standards listed by reference, including revisions by issuing authority, form a part of this specification section to the extent indicated. Standards listed are identified by issuing authority, authority abbreviation, designation number, title or other designation established by issuing authority. Standards subsequently referenced herein are referred to by issuing authority abbreviation and standard designation.

B. **<Insert applicable standards>**:

Specifier Note: Article below should be restricted to statements describing design or performance requirements and functional (not dimensional) tolerances of a complete system. Limit descriptions to composite and operational properties required to link components of a system together and to interface with other systems.

1.3 PERFORMANCE REQUIREMENTS

A. Structural Performance:

Specifier Note: Specifier Note: Edit language in paragraph below to suit project requirements.

B. Fire Resistance Rating:

1. Three-hour rating, tested and listed by [**Factory Mutual (FM)**][**Underwriters Laboratories (UL)**][**Canadian Underwriters Laboratories (C-UL)**] [**where indicated**]**<Insert locations>**.

Specifier Note: Article below includes submittal of relevant data to be furnished by Contractor before, during or after construction. Coordinate this article with Architect's and Contractor's

[duties and responsibilities in Conditions of the Contract and Division 1 Submittal Procedures Section.](#)

1.4 SUBMITTALS

A. General: Submit listed submittals in accordance with Conditions of the Contract and Division 1 Submittal Procedures Section.

B. Product Data: Submit manufacturer's product data and installation instructions.

C. Shop Drawings: Provide drawings indicating guide details, head and jamb conditions, clearances, anchorage, accessories, finish colors, patterns and textures, operator mounts and other related information.

D. Quality Assurance Submittals: Submit the following:

1. Certificates: Submit manufacturer's certificate that products meet or exceed specified requirements.
2. Certificates: Submit installer qualifications.

E. Closeout Submittals: Submit the following:

1. Warranty documents available at www.raynor.com or from your authorized Raynor dealer.

[Specifier Note: Installation of Raynor Doors should be performed by an authorized Raynor Dealer. Coordinate article below with Division 1 Quality Assurance Section.](#)

1.5 QUALITY ASSURANCE

A. Installer Qualifications: Utilize an installer having demonstrated experience on projects of similar size and complexity, and trained and authorized by the door manufacturer to perform the work of this section.

[Specifier Note: Paragraph below should list obligations for compliance with specific code requirements particular to this section. General statements to comply with a particular code are typically addressed in Conditions of the Contract and Division 1 Regulatory Requirements Section. Repetitive statements should be avoided.](#)

B. Regulatory Requirements and Approvals: **<Insert applicable requirements of regulatory agencies.>**Listed by [Underwriters Laboratories (UL)] [Canadian Underwriters Laboratories (C-UL)] [California State Fire Marshal (CSFM)] [City of New York Material and Equipment Acceptance (MEA)].<

[Specifier Note: Retain paragraph below if preinstallation meeting is required.](#)

C. Preinstallation Meetings: <Insert requirements for meeting>. Verify project requirements, substrate conditions, manufacturer's installation instructions and manufacturer's warranty requirements. Comply with Division 1 Project Management and Coordination (Project Meetings) Section.

Specifier Note: Article below should include specific protection and environmental conditions required during product storage. Coordinate article below with Division 1 Product Requirements Section.

1.6 DELIVERY, STORAGE & HANDLING

A. General: Comply with Division 1 Product Requirements.

B. Comply with manufacturer's ordering instructions and lead time requirements to avoid construction delays.

C. Delivery: Deliver materials in manufacturer's original, unopened, undamaged containers with identification labels intact.

D. Storage and Protection: Store materials protected from exposure to harmful environmental conditions and at temperature and humidity conditions recommended by the manufacturer.

Specifier Note: Coordinate article below with Conditions of the Contract and with Division 1 Closeout Submittals (Warranty) Section. Use this article to require special or extended warranty or bond covering the work of this section.

1.7 WARRANTY

A. Project Warranty: Refer to Conditions of the Contract for project warranty provisions.

B. Manufacturer's Warranty: Submit, for Owner's acceptance, manufacturer's standard warranty document executed by authorized company official. Manufacturer's warranty is in addition to, and not a limitation of, other rights Owner may have under contract documents.

Specifier Note: Retain, edit or delete article below to suit project and specifier practice.

1.8 MAINTENANCE

A. Extra Materials: Provide additional material for use by owner in building maintenance and repair. Package products with protective covering and identify with descriptive labels. Comply with Division 1 Closeout Submittals (Maintenance Materials) Section.

1. Quantity: <Insert quantity requirements for additional materials.>

Specifier Note: State requirements for extended maintenance of systems or equipment to be provided by contractor.

B. Maintenance Service: Submit for Owner's consideration and acceptance maintenance service agreement for products installed.

PART 2 - PRODUCTS

Specifier Note: Retain article below for proprietary method specification. Add product attributes, performance characteristics, material standards and descriptions as applicable. Use of such phrases as "or equal" or "or approved equal" or similar phrases may cause ambiguity in specifications. Such phrases require verification (procedural, legal and regulatory) and assignment of responsibility for determining "equal" products.

2.1 MANUFACTURER

Specifier Note: Paragraph below is a recommended addition to CSI SectionFormat. Retain, edit or delete paragraph below to suit project requirements and specifier practice.

A. Manufacturer: Raynor Door.

1. Contact: P.O. Box 448, 1101 East River Road, Dixon, IL 61021-0448;
Telephone: (800) 472-9667, (815) 288-1431; Fax: (815) 288-7142; E-mail:
thegarage@raynor.com; website: www.raynor.com.

B. Manufacturer Product Designation: FIRECURTAIN STANDARD.

2.2 DOOR OPERATORS

A. Provide doors designed for [**manual**] [**hand crank**] [**tube motor**] operation.

1. Drive Orientation: For hand-chain, hand-crank or electric tube motor operated doors, orient the drive from the [**left-hand**] [**right-hand**] side when facing the reference side of the door (side with counterbalance or hood exposed).

Specifier Note: The FireEclipse Tube Motor is concealed inside the barrel assembly and effectively replaces traditional torsion spring counterbalance system.

B. Manufacturer Product Designation: Raynor FireEclipse Tube Motor:

1. Type: Tube Motor
2. Electrical Requirements: [**115 volt single**] phase.
3. Control Wiring: [**Two button constant pressure "open-close"(Special wiring is available)**].

2.3 CURTAIN

A. Material: Interlocking slats, roll formed from 22 gauge (0.030 inch steel thickness) commercial quality hot-dipped galvanized (G-90) steel complying with ASTM A-653.

B. Mounting: [**Face Mounting: fasten to face of wall on each side of door opening**] [**Between-Jamb Mounting: fasten between jambs of wall opening**].

Specifier Note: Rolling fire counter shutter may be provided with an integral frame, with the shutter factory pre-installed in a completed frame assembly.

C. Integral Frame: Provide frame as follows: [**Painted Slip-in Frame for use with a pre-existing finished opening**] [**Painted Build-in Frame for use with masonry wall construction**].

D. Color and Finish: [**Gray polyester paint applied over one coat white epoxy primer**] [**ArmorBrite Powdercoat <Insert color.>**]

E. Endlocks: Lateral movement of the slats to be contained by means of zinc-plated stamped steel endlocks fastened to slat.

F. Bottom Bar and Seal: Roll-formed painted tubular steel type, with 1/4 inch (6.3 mm) thick protective strip to cushion impact of bottom bar on counter top. Finish to match shutter curtain.

2.4 GUIDES

A. Guide Assemblies: Guides shall consist of 13 gauge (.086 inch minimum thickness) steel, formed from galvanized steel and finished to match curtain.

B. Jamb Construction: [**Steel Jambs with self-tapping fasteners**] [**Masonry Jambs with anchor bolt fasteners**] [**Non-masonry Jambs for jambs consisting of drywall or plaster (fasteners included)**].

2.5 COUNTERBALANCE SYSTEM

A. Headplates: Mounting brackets shall be made from 10 gauge galvanized steel plate and attached to the wall and guide.

B. Barrel: Minimum 4-1/2 inches (114.3 mm) O.D. and 0.120 inch (3.1 mm) wall thickness structural steel pipe. Deflection of pipe under full load shall not exceed 0.03 inch (0.8 mm) per foot of span.

C. Counterbalance: [**Torsion Spring: Oil-tempered, helical torsion springs, grease packed and mounted on a continuous steel torsion shaft.**] [**Tube Motor operation (see 2.2 Door Operators).**]

2.6 ENCLOSURES

- A. Hood: Furnish rolling fire counter shutter with a square hood enclosure fabricated from 24 gauge steel, finish painted to match curtain.
- B. Headplate Cover: Rolling fire counter shutter shall be furnished with an enclosure for the headplates, consisting of 24 gauge steel finish-painted to match the curtain.

2.7 RELEASE SYSTEM

- A. Descent Control: Rolling fire counter shutter operation mechanism shall be disengaged during automatic closing of the shutter. Descent of shutter under fire conditions shall be controlled by: [**Centrifugal Governor**].
- B. Release Type: Automatic closing of rolling fire counter shutter under fire conditions to be initiated by: [**Fusible Links**] [**Thermal-Manual Links**] [**Electro-Thermal Manual Links with Junction Box**] [**Electro-Thermal Manual Links without Junction Box**] [**FireShield (optional on FireEclipse)**] [**LM90 Model A**].
- C. Detection Type: Device used in conjunction with the release type to initiate the automatic closing of rolling fire counter shutter: [Ionization Smoke Detector] [Photoelectronic with Heat Sensor Detector].

2.8 HARDWARE

Specifier Note: Rolling fire counter shutter may be provided with locking device. Retain or delete paragraph below to suit project requirements.

Locks: Furnish counter shutter with: [**Locking Bar, to receive padlock provided by owner, for use with manual and hand crank operated shutters.**] [**Cylinder Lock for use with manual and hand crank operated doors.**].

PART 3 - EXECUTION

Specifier Note: Article below is a recommended addition to CSI SectionFormat. Revise article below to suit project requirements and specifier's practice.

3.1 MANUFACTURER'S INSTRUCTIONS

- A. Comply with instructions and recommendations of door manufacturer.

Specifier Note: Specify requirements where an unusually high quality of workmanship is required. Retain article below and list local Raynor dealer installers as required to suit project requirements and specifier practice.

3.2 ACCEPTABLE INSTALLERS

A. **<Insert acceptable installers.>**

Specifier Note: Specify actions to physically determine that conditions are acceptable to receive primary products of the section.

3.3 EXAMINATION

A. Site Verification of Conditions: Verify through direct observation and field measurement that site conditions are acceptable for installation of doors, operators, controls and accessories. Ensure that openings square, flush and plumb.

B. Do not proceed with installation of doors, operators, controls and accessories until unacceptable conditions are corrected.

Specifier Note: Coordinate article below with manufacturer's recommended installation requirements. All door installations should be performed by an authorized Raynor Dealer. Consult Raynor to obtain local dealer contact information. Preparation of door openings should comply with submitted Raynor requirements.

3.4 INSTALLATION

A. General: Install door, guide and operating equipment complete with all necessary accessories and hardware according to shop drawings, manufacturer's instructions.

B. Site Tolerances: **<Insert applicable site tolerances for installation of specified products.>**

C. Related Products Installation: Refer to Related Sections paragraph for related products installation.

Specifier Note: Retain, edit or delete paragraph below to suit project requirements and specifier practice. Specify the tests and inspections required for installed or completed work. Establish number and duration of periodic site visits with Owner and manufacturer, and specify below. Consult with manufacturer for services required. Coordinate paragraph below with Division 1 Quality Assurance Section and Part 1 Quality Assurance Submittals.

3.5 FIELD QUALITY CONTROL

A. Manufacturer's Field Services: At Owner's request, provide manufacturer's field service consisting of product installation and use recommendations, and periodic site

visits to observe and ensure product installation is done in accordance with manufacturer's recommendations.

1. Site Visits: <**Insert number and duration of periodic site visits.**>

3.6 ADJUSTING

A. General: Lubricate bearings and sliding parts, and adjust doors for proper operation, balance, clearance and similar requirements.

Specifier Note: Specify the final actions required to clean installed equipment or other completed work to properly function or perform. Coordinate article below with Division 1 Execution Requirements (Cleaning) Section.

3.7 CLEANING

A. Remove temporary coverings and protection of adjacent work areas. Repair or replace installed products damaged prior to or during installation.

B. Clean installed products in accordance with manufacturer's instructions prior to Owner's acceptance. Remove and legally dispose of construction debris from project site.

END OF SECTION